

PAT Report Passes For all Sites and Locations

CLIENT DETAILS	
Company Name:	Tangerine Events Ltd
Address:	1 Hampton Road Twickenham Middlesex TW2 5QE



DETAIL OF CONTRACTOR RESPONSIBLE FOR TESTING			
Company Name:	Abracadabra Sound & Light		
Address:	314 Nelson Road Whitton Middlesex TW2 7AH	Telephone:	020 8893 3313
		Mobile:	07860 465769
		Email:	pattesting@abra.co.uk
Cert Number:	1-270318	Signature:	
Order Number:			
File Name:	Download 13 April 2018 00-16		

PAT TESTER DETAILS			
Serial Number	Make and Model	Certificate Number	Calibration Due Date
31C-0976			

APPLIANCE DETAILS AND TEST RESULTS										
Key P = PASS / F = FAIL / S = SKIP (or test not applicable)										
Appliance Id	Appliance Description	Test Date	Visual	Polarity	Earth Continuity (Ohms)	Insulation (MOhms)	Load (kVA)	Leakage (mA)	Overall Status	
TANGERINE EVENT - WAREHOUSE										
4269	IEC LEAD	27/03/18	P	P	P 0.04	P >99.99	S	S	PASS	
4270	HK LINEAR 2000	27/03/18	P	S	P 0.08	P >99.99	P <0.05	P <0.10	PASS	
4271	YAMAHA SUB	27/03/18	P	S	P 0.10	P >99.99	P 0.15	P 0.35	PASS	
4272	YAMAHA TOP	27/03/18	P	S	P 0.09	P >99.99	P 0.15	P 0.35	PASS	
4273	YAMAHA TOP	27/03/18	P	S	P 0.08	P >99.99	P 0.16	P 0.34	PASS	
4274	YAMAHA SUB	27/03/18	P	S	P 0.08	P >99.99	P 0.15	P 0.33	PASS	
4275	CHAUVET RADIUS 2	27/03/18	P	S	P 0.08	P >99.99	P 0.09	P 0.14	PASS	
4276	CHAUVET HAZER	27/03/18	P	S	P 0.10	P >99.99	P 0.84	P <0.10	PASS	
4277	EXTENSION LEAD	27/03/18	P	P	P 0.05	P >99.99	S	S	PASS	
4278	IEC EXTENSION	27/03/18	P	P	P 0.10	P >99.99	S	S	PASS	
4279	IEC LEAD	27/03/18	P	P	P 0.04	P >99.99	S	S	PASS	
4280	IEC LEAD	27/03/18	P	P	P 0.04	P >99.99	S	S	PASS	
4281	IEC LEAD	27/03/18	P	P	P 0.04	P >99.99	S	S	PASS	
4282	IEC LEAD	27/03/18	P	P	P 0.04	P >99.99	S	S	PASS	
4283	IEC LEAD	27/03/18	P	P	P 0.02	P >99.99	S	S	PASS	
4284	POWERCON MAINS	27/03/18	P	P	P 0.03	P >99.99	S	S	PASS	
4285	HK AKTOR 112	27/03/18	P	S	P 0.07	P >99.99	P <0.05	P <0.10	PASS	
4286	HK AKTOR SUB	27/03/18	P	S	P 0.06	P >99.99	P <0.05	P <0.10	PASS	
4287	PRESONUS DESK	27/03/18	P	S	P 0.12	P >99.99	P 0.06	P 0.15	PASS	

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

Appliance Id	Appliance Description	Test Date	Visual	Polarity	Earth Continuity (Ohms)	Insulation (MOhms)	Load (kVA)	Leakage (mA)	Overall Status
4288	IEC LEAD	27/03/18	P	P	P 0.02	P >99.99	S	S	PASS
4289	IEC EXTENSION	27/03/18	P	P	P 0.05	P >99.99	S	S	PASS
4290	IEC LEAD	27/03/18	P	P	P 0.07	P >99.99	S	S	PASS
4291	CHAUVET PAR BAR	27/03/18	P	S	P 0.08	P >99.99	P <0.05	P <0.10	PASS
4292	CHAUVET PAR BAR	27/03/18	P	S	P 0.08	P >99.99	P <0.05	P <0.10	PASS
4293	DOTZ TBAR	27/03/18	P	S	P 0.08	P >99.99	P 0.07	P 0.20	PASS
4294	PROFILE PANEL	27/03/18	P	S	P 0.08	P >99.99	P 0.08	P 0.14	PASS
4295	PROFILE PANEL	27/03/18	P	S	P 0.09	P >99.99	P 0.10	P 0.14	PASS
4296	CHAUVET 4BAR	27/03/18	P	S	P 0.08	P >99.99	P <0.05	P <0.10	PASS
4297	CHAUVET 4BAR	27/03/18	P	S	P 0.08	P >99.99	P <0.05	P <0.10	PASS
4298	KAM RODEO	27/03/18	P	S	P 0.08	P >99.99	P <0.05	P 0.23	PASS
4299	IEC LEAD	27/03/18	P	P	P 0.04	P >99.99	S	S	PASS
4300	ADJ DOTZ TPAR	27/03/18	P	S	P 0.08	P >99.99	P 0.06	P 0.18	PASS
4301	EXTENSION LEAD	27/03/18	P	P	P 0.08	P >99.99	S	S	PASS
4302	IEC LEAD	27/03/18	P	P	P 0.04	P >99.99	S	S	PASS
4303	PRESONUS MIXER	27/03/18	P	S	P 0.08	P >99.99	P 0.06	P 0.18	PASS
4304	IEC LEAD	27/03/18	P	P	P 0.03	P >99.99	S	S	PASS
4305	PROFILE PANEL	27/03/18	P	S	P 0.07	P >99.99	P 0.31	P 0.44	PASS
4306	PROFILE PANEL	27/03/18	P	S	P 0.08	P >99.99	P 0.46	P 0.33	PASS
4307	BASS AMP	27/03/18	P	S	P 0.09	P >99.99	P <0.05	P <0.10	PASS
4308	RH450	27/03/18	P	S	P 0.09	P >99.99	P 0.10	P 0.42	PASS
4309	HKSUB	27/03/18	P	S	P 0.07	P >99.99	P <0.05	P <0.10	PASS
4310	HKSUB	27/03/18	P	S	P 0.07	P >99.99	P <0.05	P <0.10	PASS
4311	HKSUB	27/03/18	P	S	P 0.07	P >99.99	P <0.05	P <0.10	PASS
4312	HKTOP	27/03/18	P	S	P 0.07	P >99.99	P 0.08	P 0.58	PASS
4313	HKSUB	27/03/18	P	S	P 0.07	P >99.99	P 0.08	P 0.55	PASS
4314	CHAUVET CORE 4	27/03/18	P	S	P 0.08	P >99.99	P 0.08	P 0.35	PASS
4315	ADJ DOTZ TPAR	27/03/18	P	S	P 0.08	P >99.99	P 0.07	P 0.19	PASS
4316	TRIPAR DOTZ	27/03/18	P	S	P 0.08	P >99.99	P 0.07	P 0.20	PASS
4317	BEHRINGER X32	27/03/18	P	S	P 0.10	P >99.99	P <0.05	P <0.10	PASS
4318	KAM LED RODEO	27/03/18	P	S	P 0.08	P >99.99	P 0.06	P 0.20	PASS
4319	QTX HZ3	27/03/18	P	S	P 0.08	P >99.99	P <0.05	P <0.10	PASS
4320	UV CANNON	27/03/18	P	S	P 0.08	P >99.99	P 1.59	P <0.10	PASS

Total Appliances > **52**

Total Appliances For Report: 52