

PAT Report Passes For all Sites and Locations

CLIENT DETAILS	
Company Name:	Tangerine Events Ltd
Address:	1 Hampton Road Twickenham Middlesex TW2 5QE



DETAIL OF CONTRACTOR RESPONSIBLE FOR TESTING			
Company Name:	Abracadabra Sound & Light		
Address:	314 Nelson Road Whitton Middlesex TW2 7AH	Telephone:	020 8893 3313
		Mobile:	07860 465769
		Email:	pattesting@abra.co.uk
Cert Number:	1-031101	Signature:	
Order Number:			
File Name:			

PAT TESTER DETAILS			
Serial Number	Make and Model	Certificate Number	Calibration Due Date
31C-0976			

APPLIANCE DETAILS AND TEST RESULTS										
Key P = PASS / F = FAIL / S = SKIP (or test not applicable)										
Appliance Id	Appliance Description	Test Date	Visual	Polarity	Earth Continuity (Ohms)	Insulation (MOhms)	Load (kVA)	Leakage (mA)	Overall Status	
ABRACADABRA - OFFICE										
01626	IEC LEAD	21/02/25	P	P	P 0.04	P >99.99	S	S	PASS	
01627	MIER	21/02/25	P	S	P 0.09	P >99.99	P <0.05	P 0.57	PASS	
01628	IEAR5	21/02/25	P	S	P 0.09	P >99.99	P 0.11	P 0.20	PASS	
01629	ASS I	21/02/25	P	S	P 0.09	P >99.99	P <0.05	P <0.10	PASS	
01630	TOP	21/02/25	P	S	P 0.09	P >99.99	P 0.12	P 0.20	PASS	
01632	SU	21/02/25	P	S	P 0.09	P >99.99	P <0.05	P <0.10	PASS	
01633	SU	21/02/25	P	S	P 0.08	P >99.99	P <0.05	P <0.10	PASS	
01634	IGHT AR	21/02/25	P	S	P 0.08	P >99.99	P 0.08	P 0.19	PASS	
01635	MOIG HEAD AR	21/02/25	P	S	P 0.09	P >99.99	P <0.05	P <0.10	PASS	
01636	MOIG HEAD AR	21/02/25	P	S	P 0.08	P >99.99	P <0.05	P <0.10	PASS	
01638	YOP	21/02/25	P	S	P 0.08	P >99.99	P 0.10	P 0.19	PASS	
01639	MOIG HEAD AR	21/02/25	P	S	P 0.08	P >99.99	P 0.20	P 0.31	PASS	
01640	MOIG HEAD AR	21/02/25	P	S	P 0.08	P >99.99	P <0.05	P <0.10	PASS	
01641	DOT AR	21/02/25	P	S	P 0.08	P >99.99	P 0.13	P 0.18	PASS	
01643	IEAR 115 FA	21/02/25	P	S	P 0.08	P >99.99	P 0.10	P 0.20	PASS	
01644	ASS I	21/02/25	P	S	P 0.09	P >99.99	P <0.05	P <0.10	PASS	
01645	ASS I	21/02/25	P	S	P 0.08	P 70.13	P <0.05	P <0.10	PASS	
01646	ASS I	21/02/25	P	S	P 0.09	P >99.99	P <0.05	P <0.10	PASS	
01647	ASS	21/02/25	P	S	P 0.10	P 54.04	P <0.05	P <0.10	PASS	

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

Appliance Id	Appliance Description	Test Date	Visual	Polarity	Earth Continuity (Ohms)	Insulation (MOhms)	Load (kVA)	Leakage (mA)	Overall Status
01648	EUME8 KUDOS	21/02/25	P	S	P 0.09	P >99.99	P 0.16	P 0.50	PASS
01649	EUME8 KUDIS 700	21/02/25	P	S	P 0.09	P >99.99	P <0.05	P <0.10	PASS
01650	MOIG HEAD AR	21/02/25	P	S	P 0.08	P >99.99	P 0.17	P 0.28	PASS
01651	HAE MAHIE	21/02/25	P	S	P 0.09	P >99.99	P 1.73	P <0.10	PASS
01652	ORE PAR4	21/02/25	P	S	P 0.10	P >99.99	P 0.08	P 0.34	PASS
01653	MOIG HEAG AR	21/02/25	P	S	P 0.08	P >99.99	P <0.05	P <0.10	PASS
01654	HK SU	21/02/25	P	S	P 0.08	P >99.99	P 0.11	P 0.24	PASS
01655	HK TOP	21/02/25	P	S	P 0.08	P >99.99	P 0.11	P 0.14	PASS
01656	HK SU	21/02/25	P	S	P 0.09	P >99.99	P 0.11	P 0.24	PASS
01657	HK SU	21/02/25	P	S	P 0.09	P >99.99	P <0.05	P <0.10	PASS
01658	HK TOP	21/02/25	P	S	P 0.08	P >99.99	P <0.05	P <0.10	PASS
01659	EUME8	21/02/25	P	S	P 0.09	P >99.99	P <0.05	P <0.10	PASS
01660	EUME8 KUDOS 7000	21/02/25	P	S	P 0.09	P >99.99	P 0.15	P 0.48	PASS
01661	HK SU	21/02/25	P	S	P 0.08	P >99.99	P <0.05	P <0.10	PASS
01662	QU16	21/02/25	P	S	P 0.09	P >99.99	P 0.05	P 0.58	PASS

Total Appliances > **34**

Total Appliances For Report: 34